

# **ASSE Standard #1069**

**Issued: January, 2005**

## **Performance Requirements for Automatic Temperature Control Mixing Valves**

### **Errata Sheet**

**Issued: DRAFT**

#### **3.6.3 Criteria**

Failure of the device to reduce the flow at the outlet to 0.5 GPM (1.9 L/min) or less for devices 3/4 inch (19.0 mm) and smaller, and 1.0 GPM (3.8 L/m) or less for devices larger than 3/4 inch (19.0 mm) ~~and larger~~ prior to the outlet temperature at T3 exceeding 120.0 °F (48.9 °C) shall result in a rejection of the device.