

CHAPTER 10

TRAPS AND INTERCEPTORS

1001.0 Traps Required.

1001.1 Each plumbing fixture, excepting those having integral traps or as permitted in Section 1001.2, shall be separately trapped by an approved type of water seal trap. Not more than one (1) trap shall be permitted on a trap arm.

1001.2 One (1) trap shall be permitted to serve a set of not more than three (3) single compartment sinks or laundry tubs of the same depth or three (3) lavatories immediately adjacent to each other and in the same room if the waste outlets are not more than thirty (30) inches (762 mm) apart and the trap is centrally located when three (3) compartments are installed.

1001.3 No food waste disposal unit shall be installed with any set of restaurant, commercial, or industrial sinks served by a single trap; each such food waste disposal unit shall be connected to a separate trap. Each domestic clothes washer and each laundry tub shall be connected to a separate and independent trap, except that a trap serving a laundry tub shall be permitted to also receive the waste from a clothes washer set adjacent thereto. No clothes washer or laundry tub shall be connected to any trap for a kitchen sink.

1001.4 The vertical distance between a fixture outlet and the trap weir shall be as short as practicable, but in no case shall the tailpiece from any fixture exceed twenty-four (24) inches (610 mm) in length.

1002.0 Traps Protected by Vent Pipes.

1002.1 Each plumbing fixture trap, except as otherwise provided in this code, shall be protected against siphonage, back-pressure, and air circulation shall be

assured throughout all parts of the drainage system by means of a vent pipe installed in accordance with the requirements of this code.

1002.2 Each fixture trap shall have a protecting vent so located that the developed length of the trap arm from the trap weir to the inner edge of the vent shall be within the distance given in Table 10-1, but in no case less than two (2) times the diameter of the trap arm.

1002.3 A trap arm shall be permitted to change direction without the use of a cleanout when such change of direction does not exceed 90 degrees (1.6 rad). All horizontal changes in direction of trap arms shall comply with Section 706.3.

Exception: For trap arms three (3) inches (80 mm) in diameter and larger, the change of direction shall not exceed 135 degrees (2.36 rad) without the use of a cleanout.

1002.4 The vent pipe opening from a soil or waste pipe, except for water closets and similar fixtures, shall not be below the weir of the trap.

1003.0 Traps — Described.

1003.1 Each trap, except for traps within an interceptor or similar device shall be self-cleaning. Traps for bathtubs, showers, lavatories, sinks, laundry tubs, floor drains, urinals, drinking fountains, dental units, and similar fixtures shall be of standard design, weight and shall be of ABS, cast brass, cast iron, lead, PP, PVC, or other approved material. An exposed and readily accessible drawn-brass tubing trap, not less than 17 B & S Gauge (0.045 inch) (1.1

TABLE 10-1
Horizontal Lengths of Trap Arms
(Except for water closets and similar fixtures)*

Trap Arm Pipe Diameter	Distance		Trap Arm Pipe Diameter	Distance	
	Trap to Vent Minimum	Length Maximum		Trap to Vent Minimum	Length Maximum
1-1/4"	2-1/2"	30" (2'-6")	32 mm	64 mm	762 mm
1-1/2"	3"	42" (3'-6")	40 mm	76 mm	1,067 mm
2"	4"	60" (5'-0")	50 mm	102 mm	1,524 mm
3"	6"	72" (6'-0")	80 mm	152 mm	1,829 mm
4"	8"	120" (10'-0")	100 mm	203 mm	3,048 mm
Exceeding 4"	2 x Diameter	120" (10'-0")	Exceeding 100 mm	2x Diameter	3,048 mm

Maintain one-fourth (1/4) inch per foot slope (20.8 mm/m)

* The developed length between the trap of a water closet or similar fixture (measured from the top of the closet flange to the inner edge of the vent) and it's vent shall not exceed six (6) feet (1,829 mm)

mm), shall be permitted to be used on fixtures discharging domestic sewage.

Exception: Drawn-brass tubing traps shall not be used for urinals. Each trap shall have the manufacturer's name stamped legibly in the metal of the trap, and each tubing trap shall have the gauge of the tubing in addition to the manufacturer's name. Every trap shall have a smooth and uniform interior waterway.

1003.2 A maximum of one (1) approved slip joint fitting shall be permitted to be used on the outlet side of a trap, and no tubing trap shall be installed without a listed tubing trap adapter. Listed plastic trap adapters shall be permitted to be used to connect listed metal tubing traps.

1003.3 The size (nominal diameter) of a trap for a given fixture shall be sufficient to drain the fixture rapidly, but in no case less than nor more than one (1) pipe size larger than given in Table 7-3. The trap shall be the same size as the trap arm to which it is connected.

1004.0 Traps – Prohibited.

No form of trap that depends for its seal upon the action of movable parts shall be used. No trap that has concealed interior partitions, except those of plastic, glass, or similar corrosion-resisting material, shall be used. "S" traps, bell traps, and crown-vented traps shall be prohibited. No fixture shall be double trapped. Drum and bottle traps shall be installed only for special conditions. No trap shall be installed without a vent, except as otherwise provided in this code.

1004.1 Bladders, check valves or any other type of devices with moveable parts shall be prohibited to serve as a trap.

1005.0 Trap Seals.

Each fixture trap shall have a liquid seal of not less than two (2) inches (51 mm) and not more than four (4) inches (102 mm), except where a deeper seal is found necessary by the Authority Having Jurisdiction. Traps shall be set true with respect to their liquid seals and, where necessary, they shall be protected from freezing.

1006.0 Floor Drain Traps

Floor drains, floor sinks, funnel drains and similar fixtures shall connect into a trap so constructed that it can be readily cleaned and of a size to serve efficiently the purpose for which it is intended. The drain inlet shall be so located that it is at all times in full view.

Traps for floor drains, floor sinks, funnel drains, area drains, catch basins and receptors within a building

discharging to a vented horizontal soil or waste pipe are exempt from the provision requiring individual vents for each trap, provided that the trap arm, or distance from the trap to the vented horizontal soil or waste pipe to which it discharges, measuring the developed length, does not exceed the maximum distances as shown in Table 10-1.1, and that the branch waste pipe from the trap connects to a soil or waste pipe which is vented with a pipe having a diameter not less than that which would be required to vent a floor drain, floor sink, funnel drain, area drain, catch basin and receptors, computed on the units allowed in Tables 7-3 and 7-5. Common vent sizing shall be the sum of fixture units served, but in no case smaller than the minimum vent size required for any fixture served or as determined from Table 75 whichever is larger.

Exception: Floor sinks installed to receive the discharge waste from sinks may be individually vented. Trap arms shall not exceed distances as per Table 10-1.1. Priming of traps for above vented floor sinks are not required.

**TABLE 10-1.1
Floor Drains**

Maximum Horizontal Distance to Vent or Vented Line		
Trap Size (I.D.)	Waste Branch Size (I.D.)	Maximum Dist.
2 inch (50mm)	2 inch (50mm)	6 feet (1.8m)
3 inch (75mm)	3 inch (75mm)	10 feet (3m)
4 inch (100mm)	4 inch (100mm)	14 feet (4.5m)
6 inch (150mm)	6 inch (150mm)	20 feet (6m)

Vents are not required for traps for exterior area drains and catch basins which discharge to a storm water drain system.

Cleanouts required in Section 706 do not apply when utilizing Table 10-1. 1, except for catch basins.

1007.0 Trap Seal Protection

1007.1 Floor drain or similar traps directly connected to the drainage system shall be provided with an approved automatic means of maintaining their water seals.

1007.2 Each nonpressure-activated primer valve, similar operated device, or toilet flush primer connection shall serve no more than two traps, unless a specific non-pressure activated primer valve, similarly operated device, or toilet flush primer is approved for a limited number of traps by the Administrative Authority. Pressure-activated primer valves shall be limited to the number of traps to be served as approved by the Administrative Authority for that specific valve.

1007.3 Supply piping between the priming device connection and the trap shall be at least three-eighths (3/8) inch (12mm) I.D. The supply piping to priming devices shall be protected against any form of cross-connection and sized according to the primer device manufacturer's recommendation.

1007.4 Primer valve bodies shall be installed a minimum of twelve (12) inches (0.3m) above the flood level rim of the fixture being served and in an accessible location.

1007.5 Primer headers for three or more traps shall be the "inverted manifold" type (or other approved method) having equal water flow to all outlets, with each outlet provided with a threaded removable plug or cap inspection fitting. Approved flush tanks may be used as an alternate supply source for primer headers.

1007.6 Any primer stop, if used, must be an accessible screwdriver stop.

1008.0 Building Traps.

Building traps shall not be installed except where required by the Authority Having Jurisdiction. Each building trap when installed shall be provided with a cleanout and with a relieving vent or fresh-air intake on the inlet side of the trap, which need not be larger than one-half the diameter of the drain to which it connects. Such relieving vent or fresh-air intake shall be carried above grade and terminate in a screened outlet located outside the building.

1009.0 Industrial Interceptors (Clarifiers) and Separators.

1009.1 When Required. Interceptors (clarifiers) (including grease, oil, sand interceptors [clarifiers], etc.) shall be required by the Authority Having Jurisdiction when they are necessary for the proper handling of liquid wastes containing grease, flammable wastes, sand, solids, acid or alkaline substances, or other ingredients harmful to the building drainage system, the public or private sewer, or to public or private sewage disposal.

1009.2 Approval. The size, type, and location of each interceptor (clarifier) or separator shall be approved by the Authority Having Jurisdiction. Except where otherwise specifically permitted, no wastes other than those requiring treatment or separation shall be discharged into any interceptor (clarifier).

1009.3 Design. Interceptors (clarifiers) for sand and similar heavy solids shall be so designed and located as to be readily accessible for cleaning and shall have a water seal of not less than six (6) inches (152 mm).

1009.4 Relief Vent. Interceptors (clarifiers) shall be so designed that they will not become air-bound if

closed covers are used. Each interceptor (clarifier) shall be properly vented.

1009.5 Location. Each interceptor (clarifier) cover shall be readily accessible for servicing and maintaining the interceptor (clarifier) in working and operating condition. The use of ladders or the removal of bulky equipment in order to service interceptors (clarifiers) shall constitute a violation of accessibility. Location of all interceptors (clarifiers) shall be shown on the approved building plan.

1009.6 Maintenance of Interceptors. Interceptors shall be maintained in efficient operating condition by periodic removal of accumulated grease, scum, oil, or other floating substances and solids deposited in the interceptor.

1009.7 Discharge. The waste pipe from oil and sand interceptors shall discharge as approved by the Authority Having Jurisdiction.

1010.0 Slaughterhouses, Packing Establishments, etc.

Every fish, fowl, and animal slaughterhouse or establishment; every fish, fowl, and meat packing or curing establishment; every soap factory, tallow-rendering, fat-rendering, and hide-curing establishment shall be connected to and shall drain or discharge into an approved grease interceptor (clarifier).

1011.0 Minimum Requirements for Auto Wash Racks.

Every private or public wash rack and/or floor or slab used for cleaning machinery or machine parts shall be adequately protected against storm or surface water and shall drain or discharge into an approved interceptor (clarifier).

1012.0 Commercial and Industrial Laundries.

Laundry equipment in commercial and industrial buildings that does not have integral strainers shall discharge into an interceptor having a wire basket or similar device that is removable for cleaning and that will prevent passage into the drainage system of solids one-half (1/2) inch (12.7 mm) or larger in maximum dimension, such as string, rags, buttons, or other solid materials detrimental to the public sewerage system.

1013.0 Bottling Establishments.

Bottling plants shall discharge their process wastes into an interceptor that will provide for the separation of broken glass or other solids, before discharging liquid wastes into the drainage system.

1014.0 Grease Interceptors.

1014.1 Waste pretreatment is required in all Food Service Establishments. Waste pretreatment is also required in other establishments as determined by the Building Official, where grease is introduced into the drainage or sewer system. An approved type of grease interceptor(s) complying with the provisions of this section shall be correctly sized and properly installed. The following plumbing fixtures and drains shall be connected to the grease interceptor(s):

All plumbing fixtures, garbage disposals, dishwashers, floor drains, and cooking equipment, with drain connections in food and/or beverage preparation areas of all Food Service Establishments.

If a garbage disposal is installed on a system using a hydromechanical grease interceptor, a solids interceptor shall be installed upstream of the inlet of the grease interceptor.

When space or existing physical constraints of existing buildings necessitate such installations any combination of hydromechanical, gravity grease interceptors, and professionally engineered systems shall be allowed in order to meet this code and other applicable requirements of the Building Official. A grease interceptor shall not be required for individual dwelling units or for any private living quarters.

Exception 1: Ice wells and condensate drains are not required to drain into or through the grease interceptor(s).

Exception 2: Bathroom plumbing fixtures, including bathroom floor drains, shall not drain into or through the grease interceptor(s).

1014.1.1 Each fixture discharging into a grease interceptor shall be individually trapped and vented in an approved manner.

1014.2 Hydromechanical Grease Interceptors.

1014.2.1 Plumbing fixtures or equipment connected to a Type A and B hydromechanical grease interceptor shall discharge through an approved type of vented flow control installed in a readily accessible and visible location. Flow control devices shall be designed and installed so that the total flow through such device or devices shall at no time be greater than the rated flow of the connected grease interceptor. No flow control device having adjustable or removable parts shall be approved. The vented flow control device shall be located such that no system vent shall be between the flow control and the grease interceptor inlet. The vent or air inlet of the flow control device shall connect with the sanitary drainage vent system, as elsewhere required by this code, or shall terminate through the roof of the building, and shall not terminate to the free atmosphere inside the building.

Exception: Listed grease interceptors with integral flow controls or restricting devices shall be installed in an accessible location in accordance with the manufacturers' instructions.

1014.2.2 The total capacity in gallons (L) of fixtures discharging into any hydromechanical grease interceptor shall not exceed two and one-half (2-1/2) times the certified GPM (L/m) flow rate of the interceptor as per Table 10-2.

For the purpose of this section, the term "fixture" shall mean and include each plumbing fixture, appliance, apparatus, or other equipment required to be connected to or discharged into a grease interceptor by any provision of this section.

Note: Sizing criteria specified in this section are based upon proper maintenance of the grease interceptor(s).

TABLE 10-2
Table Hydromechanical Grease Interceptor (HGI)
Sizing Chart*

DFU	HGI Flow (gpm)
8	20
10	25
13	35
20	50
35	75
172	100
216	150
342	200
428	250
576	350
720	500

*Based on intermittent potentially full flow in drainage lines.

Table 10-3
Gravity Grease Interceptor Sizing

DFUs (1,3)	Interceptor Volume (2)
8	500 gallons
21	750 gallons
35	1,000 gallons
90	1,250 gallons
172	1,500 gallons
216	2,000 gallons
307	2,500 gallons
342	3,000 gallons
428	4,000 gallons
576	5,000 gallons
720	7,500 gallons
2112	10,000 gallons
2640	15,000 gallons

Notes

- (1) The maximum allowable DFUs plumbed to the kitchen drain lines that will be connected to the grease interceptor.
- (2) This size is based on: DFUs, the pipe size from this code; Table 7-5; Useful Tables for flow in half-full pipes (ref: *Mohinder Nayyar Piping Handbook*, 3rd Edition, 1992). Based on 30-minute retention time (ref.: George Tchobanoglous and Metcalf & Eddy. *Wastewater Engineering Treatment, Disposal and Reuse*, 3rd Ed. 1991 & Ronald Crites and George Tchobanoglous. *Small and Decentralized Wastewater Management Systems*, 1998). Rounded up to nominal interceptor volume.
- (3) When the flow rate of directly connected fixture(s) or appliance(s) have no assigned DFU values, the additional grease interceptor volume shall be based on the known flow rate (gpm) multiplied by 30 minutes.

1014.2.3 A vent shall be installed downstream of hydromechanical grease interceptors in accordance with the requirements of this code.

1014.3 Gravity Grease Interceptors. Required gravity grease interceptors shall comply with the provisions of Sections 1014.3.1 through 1014.3.7.

1014.3.1 General. The provisions of this section shall apply to the design, construction, installation, and testing of commercial kitchen gravity grease interceptors.

1014.3.2 Waste Discharge Requirements.

1014.3.2.1 Waste discharge from plumbing fixtures and equipment as required in Section 1014.1, shall be allowed to be drained into the sanitary waste through the interceptor when approved by the Building Official.

1014.3.2.2 Bathroom fixtures, toilets, urinals, and other similar fixtures shall not drain through the interceptor.

1014.3.2.3 All waste shall enter the interceptor through the inlet pipe only.

1014.3.3 Design.

1014.3.3.1 Gravity Interceptors shall be constructed in accordance with the applicable standard in Table 14-1 or the design approved by the Building Official.

1014.3.4 Location.

1014.3.4.1 Each grease interceptor shall be so installed and connected that it shall be at

all times easily accessible for inspection, cleaning, and removal of the intercepted grease. A gravity grease interceptor complying with IAPMO Z1001, shall not be installed in any part of a building where food is handled. Location of the grease interceptor shall meet the approval of the Building Official.

1014.3.4.2 Interceptors shall be placed as close as practical to the fixtures they serve.

1014.3.4.3 Each business establishment for which a gravity grease interceptor is required shall have an interceptor which shall serve only that establishment unless otherwise approved by Building Official.

1014.3.4.4 Each gravity grease interceptor shall be located so as to be readily accessible to the equipment required for maintenance.

1014.3.5 Construction Requirements.

1014.3.5.1 Purpose. Gravity grease interceptors shall be designed to remove grease from effluent and shall be sized in accordance with this section. Gravity grease interceptors shall also be designed to retain grease until accumulations can be removed by pumping the interceptor. It is recommended that a sample box be located at the outlet end of all gravity grease interceptors so that effluent quality can be sampled periodically.

1014.3.6 Sizing Criteria.

1014.3.6.1 Sizing. The volume of the interceptor shall be determined by using Table 10-3. If drainage fixture units (DFUs) are not known, the interceptor shall be sized based on the maximum DFUs allowed for the pipe size connected to the inlet of the interceptor. Refer to Table 7-5, Drainage Piping, Horizontal.

Note: Sizing criteria specified in this section are based upon proper maintenance of the grease interceptor(s).

1014.3.7 Abandoned Gravity Grease Interceptors. Abandoned grease interceptors shall be pumped and filled as required for abandoned sewers and sewage disposal facilities in Section 722.0.

1015.0 FOG (Fats, Oils, and Greases) Disposal System.

1015.1 Purpose. The purpose of this section is to provide the necessary criteria for the sizing, application, and installation of a FOG disposal system.

1015.2 Components, Materials, and Equipment. FOG disposal systems, including all components, materials, and equipment necessary for the proper function of the system, shall comply with Sections 301.1.3 or 301.2 of this code.

1015.3 Sizing Application and Installation. FOG disposal systems shall be designed, sized, and installed in accordance with the manufacturers' specifications and as specified in ASME A112.14.6, as listed in Chapter 14, Table 14-1 of this code.

1015.4 Performance. FOG disposal systems shall be tested and certified as listed in Chapter 14, Table 14-1 of this code, and other national consensus standards applicable to FOG disposal systems as discharging a maximum of 100 mg/L FOG.

Gravity Grease Interceptor Sizing Example:

Given: A restaurant with the following fixtures and equipment.

One food preparation sink; three floor drains - one in the food prep area, one in the grill area, and one receiving the indirect waste from the ice machine and a mop sink.

Kitchen Drain Line DFU Count (from Table 7-3):

3 floor drains @ 2 DFUs each =	6 DFUs
Mop sink @ 3 DFUs each =	3 DFUs
Food prep sink @ 3 DFUs each =	3 DFUs
Total	12 DFUs

Using Table 10-3, the grease interceptor will be sized at 750 gallons.

1016.0 Sand Interceptors.

1016.1 Where Required.

1016.1.1 Whenever the discharge of a fixture or drain contain solids or semi-solids heavier than water that would be harmful to a drainage system or cause a stoppage within the system, the discharge shall be through a sand interceptor. Multiple floor drains shall be permitted to discharge into one sand interceptor.

1016.1.2 Sand interceptors are required whenever the Authority Having Jurisdiction deems it advisable to have a sand interceptor to protect the drainage system.

1016.2 Construction and Size. Sand interceptors shall be built of brick or concrete, prefabricated coated steel, or other watertight material. The interceptor shall have an interior baffle for full separation of the interceptor into two (2) sections. The outlet pipe shall be the same size as the inlet pipe of the sand interceptor, the minimum being three (3) inches (80 mm), and the baffle shall have two (2) openings of the same diameter as the outlet pipe and at the same invert as the outlet pipe. These openings shall be staggered so that there cannot be a straight line flow between any inlet pipe and the outlet pipe. The invert of the inlet pipe shall be no lower than the invert of the outlet pipe.

The sand interceptor shall have a minimum dimension of two (2) feet square (0.19 m²) for the net free opening of the inlet section and a minimum depth under the invert of the outlet pipe of two (2) feet (610 mm).

For each five (5) gallons (18.9 L) per minute flow or fraction thereof over twenty (20) gallons (75.7 L) per minute, the area of the sand interceptor inlet section is to be increased by one (1) square foot (0.09 m²). The outlet section shall at all times have a minimum area of fifty (50) percent of the inlet section.

The outlet section shall be covered by a solid removable cover, set flush with the finished floor, and the inlet section shall have an open grating, set flush with the finished floor and suitable for the traffic in the area in which it is located.

1016.3 Separate Use. Sand and similar interceptors for every solid shall be so designed and located as to be readily accessible for cleaning, shall have a water seal of not less than six (6) inches (152 mm), and shall be vented.

1017.0 Oil and Flammable Liquid Interceptors.

1017.1 Interceptors Required. All repair garages and gasoline stations with grease racks or grease pits, and all factories that have oily, flammable, or both types of wastes as a result of manufacturing, storage, maintenance, repair, or testing processes, shall be provided with an oil or flammable liquid

interceptor that shall be connected to all necessary floor drains. The separation or vapor compartment shall be independently vented to the outer air. If two (2) or more separation or vapor compartments are used, each shall be vented to the outer air or shall be permitted to connect to a header that is installed at a minimum of six (6) inches (152 mm) above the spill line of the lowest floor drain and vented independently to the outer air. The minimum size of a flammable vapor vent shall be not less than two (2) inches (50 mm), and, when vented through a sidewall, the vent shall be not less than ten (10) feet (3,048 mm) above the adjacent level at an approved location. The interceptor shall be vented on the sewer side and shall not connect to a flammable vapor vent. All oil and flammable interceptors shall be provided with gastight cleanout covers that shall be readily accessible. The waste line shall be not less than three (3) inches (80 mm) in diameter with a full-size cleanout to grade. When an interceptor is provided with an overflow, it shall be provided with an overflow line (not less than two (2) inches (50 mm) in diameter) to an approved waste oil tank having a minimum capacity of five-hundred fifty (550) gallons (2,082 L) and meeting the requirements of the Authority Having Jurisdiction. The waste oil from the separator shall flow by gravity or shall be pumped to a higher elevation by an automatic pump. Pumps shall be adequately sized and accessible. Waste oil tanks shall have a two (2) inch (50 mm) minimum pump-out connection at grade and a one and one-half (1-1/2) inch (40 mm) minimum vent to atmosphere at an approved location not less than ten (10) feet (3,048 mm) above grade.

1017.2 Design of Interceptors. Each manufactured interceptor that is rated shall be stamped or labeled by the manufacturer with an indication of its full discharge rate in gpm (L/m). The full discharge rate to such an interceptor shall be determined at full flow. Each interceptor shall be rated equal to or greater than the incoming flow and shall be provided with an overflow line to an underground tank.

Interceptors not rated by the manufacturer shall have a depth of not less than two (2) feet (610 mm) below the invert of the discharge drain. The outlet opening shall have not less than an eighteen (18) inch (457 mm) water seal and shall have a minimum capacity as follows: Where not more than three (3) motor vehicles are serviced and/or stored, interceptors shall have a minimum capacity of six (6) cubic feet (0.17 m³), and one (1) cubic foot (0.03 m³) of capacity shall be added for each vehicle up to ten (10) vehicles. Above ten (10) vehicles, the Authority

Having Jurisdiction shall determine the size of the interceptor required. Where vehicles are serviced only and not stored, interceptor capacity shall be based on a net capacity of one (1) cubic foot (0.03 m³) for each one-hundred (100) square feet (9.29 m²) of surface to be drained into the interceptor, with a minimum of six (6) cubic feet (0.17 m³).

