

Technical Committees Formal Interpretations Request/Ballot Form

- Interpretation requests must pertain to the IAPMO Plumbing or Mechanical Code(s) or their appendices, except Appendix I of the UPC.
- Return completed form to:
**IAPMO Council Secretary–
Interpretations
5001 E. Philadelphia St.
Ontario, CA 91761-2816.**
- Please read carefully instructions on reverse side.
- Please allow a minimum of 90 days for ballot results

Check One Only

UPC 2003 UPC 2006

Question _____

PLEASE PRINT

Phrase question and presumed correct answer in a definitive form requiring no more than a "YES" or "NO" response. Attach additional sheets, if necessary.

Section 420.0 in the 2003 UPC indicates that the water heater thermostat cannot be considered a suitable control for meetings this provision. Is it the intent of the code that a thermostatic mixing valve that provides scald protection and conforms to ASSE 1016 is considered the only device to meet this requirement?

Signed _____ Signature on file _____

For Technical Committee Use ONLY

In response to applicant's answer to question posed, please check Yes or No.

YES

NO

Print Name: _____

Date: _____

Signature: _____

Comments:

There is more than one device that is covered under ASSE 1016 that meet the intent of this section. ASSE 1016 covers three (3) types of individual control valves pressure balancing valves (Type P), thermostatic valves (Types T) and combination thermostatic/pressure balancing valves (Type T/P)