



Summary of Substantive Changes
between the 2011 edition and Update No. 1, dated November 2011
ASME A112.18.1-2011/CSA B125.1-11, "Plumbing Supply Fittings"

Presented to the IAPMO Standards Review Committee on February 13, 2012

General: The changes are editorial and include a new definition. There should not be any affect on current listings.

Section 3.1, Definitions: Added the following definition;

Shower head — an accessory to a supply fitting for spraying water onto a bather, typically from an overhead position.

Section 5.9.3.2.2.3, Mounting: changed the text as follows;

(b) a vacuum system that can maintain a 0 to 85 kPa (0 to ~~25-in-Hg~~ 12 psi) vacuum; and

Section 5.10.6.2.4: changed the text as follows;

(e) The temperature-recording device shall be started 10 s before the ~~63.2%~~ step changes.

Table 1, Minimum and maximum flow rates:

Changed the reference in column 2 of row 12 from *See Clause 4.~~12.1~~* to *See Clause 4.11.1*