



Summary of Substantive Changes
between the 2013 and the 2013e1 editions of
**ASTM F1973, “Factory Assembled Anodeless Risers and Transition
Fittings in Polyethylene (PE) and Polyamide 11 (PA11) and
Polyamide 12 (PA12) Fuel Gas Distribution Systems”**

Presented to the IAPMO Standards Review Committee on December 9, 2013

General: The change to this standard is editorial and will not have an impact on currently listed products. The editorial change is:

- Corrected the sign of the Fahrenheit conditioning temperature from positive to negative (see Section 7.4.3)

Section 7, Test Methods: Corrected the sign of the Fahrenheit conditioning temperature as follows:
7.4.3 Condition specimens to a temperature of ~~20 ± 3.6°F~~ -20 ± 3.6°F (-29 ± 2°C) and maintain for a minimum of 2.5 h.