## American Society of Sanitary Engineering PRODUCT (SEAL) LISTING PROGRAM



# ASSE STANDARD #1016 - REVISED: 2017 Automatic Compensating Valves for Individual Showers and Tub / Shower Combinations

MANUFACTURER:	
CONTACT PERSON:	
ADDRESS:	
LABORATORY FILE NUMBER:	
MODEL # TESTED:	
MODEL SIZE:	
ADDITIONAL MODELS REPORT APPLIES TO:	
ADDITIONAL MODEL INFORMATION (i.e. orientation, series, end connect	
DATE MODELS RECEIVED BY LABORATORY:	
DATE TESTING WAS COMPLETED:	
IF MODELS WERE DAMAGED DURING SHIPMENT, DESCRIBE DAM	
PROTOTYPE OR PRODUCTION:	
WERE ALL TESTS PERFORMED AT THE SELECTED LABORATORY	
If offsite, identify location and tests involved:	

#### General information and instructions for the testing engineer:

The results within this report apply only to the models listed above.

There may be items for which the judgment of the test engineer will be involved. Should there be a question of compliance with that provision of the standard, a conference with the manufacturer should be arranged to enable a satisfactory solution of the question.

Should disagreement persist and compliance remain in question by the test agency, the agency shall, if the product is in compliance with all other requirements of the standard, file a complete report on the questionable items together with the test report, for evaluation by the ASSE Seal Board. The Seal Board will then review and rule on the question of compliance with the intent of the standard then involved.

Documentation of material compliance must be furnished by the manufacturer. The manufacturer shall furnish to the testing agency, a bill of material which clearly identifies the material of each part included in the product construction. This identification must include any standards which relate thereto.





C	C.	TI	0	NI	- 1
J	·		U	IV	-

1.1	Scope Is this device intended for point-of-use installation?	Oyes	ONo	O Quest	tionable
	Does this device provide the bather or bather's attendant temperature control?	t access to	the final flo O No	w and O Quest	tionable
	Does this device indicate that further mixing downstream	of the dev	ice is requir O No	red? O Quest	tionable
1.2	Does this device comply with the requirements of this se	ection?		Oyes	O No
SECTION III 3.1.1	Indicate the type of the individual control valve:  O Type P  O Type T  O Type P / T				
3.2	Accessible Design Is this device intended for use in accessible designs?			Oyes	O No
3.3	Minimum Rated Flow What is the minimum flow rate as stated by the manufac	cturer?	GPM	l	_L/min)
3.4	Pressure What is the rated design pressure as stated by the manu	facturer?	psi		kPa)
3.5	Temperature What are the incoming hot and cold water temperature remanufacturer?	equirements	s as stated	by the	
	Hot Water: °F to °F ( °	C to	°C)		
	Cold Water: °F to °F ( °	C to	°C)		
	Is the device equipped with an adjustable means to limit the hot position?	the setting	of the devi	ce toward O Yes	s O No
	Is the device intended to be the final temperature control	?		O Yes	O No
SECTION IV 4.1	General Were all tests conducted on the same device and were the this Standard?	he tests cor	_	he order I Yes	isted in O No
4.2	Conditioning Was the device conditioned at ambient laboratory conditional conditions are conditioned at ambient laboratory.	ions for not	less than 1	2 hours? O Yes	O No





	Was the device set-up in accordance with Figure	a 1 with chut-off valves V1 a	nd V2 and valve
	- · · · · · · · · · · · · · · · · · · ·	; I With Shut-on valves vi a	
	V#3 in the full open position?		O Yes O No
	Incoming hot water pressure	psi	( kPa)
	Incoming cold water pressure	psi	
	Incoming hot water temperature	°F	
	Incoming cold water temperature		` ——————
	mooning cold trater tomperature		(
	Maximum allowable outlet temperature	°F	( °C)
	Valve V3 was adjusted to reduce the flow rate t	.co GPM	(L/min)
	Water at these conditions was then allowed to f	low through the device for	min
4.3	Working Pressure Test		
	With the device's valve in the fully open position	n and the outlet blocked, the	device was
	subjected to pressures of	psi	(kPa)
	and	psi	( kPa)
	at a temperature of	^°F	( °C)
	for		minutes each,
	and then to pressures of	psi	(kPa)
	and	psi	(kPa)
	at a temperature of	°F	(°C)
	for		minutes each.
4.3.2	What were the pressures used with closed valve Cold Inlet: Hot Inlet: What was the duration for each?	es? psi psi	· · · · · · · · · · · · · · · · · · ·
4.4	Maximum Operating Torque or Force Adjustmen What was the maximum allowable force or torque to open, operate and close a device?		8.1/CSA B125.1
	Rotary Torque:		
	Axial Force:		
	The ASME A112.18.1/CSA B125.1 Clause 5.5 to	ests were run at pressures and	d temperatures of:
	psi ( kPa) ar	nd °F	( °C)
	··································		
	·		· —
	psi (kPa) ar	nd °F	(
	Following the tests specified in Clause 5.5 of Asset up and tested as specified in items (a) to (f)		
	Was the adjusting mechanism of the device mov testing?	red through its full operating	range during this O Yes O No





What was the maximum actual torque or force required to adjust the device per Clause 5.5 of ASME A112.18.1/CSA B125.1 and during testing of (a) to (f) of Section 4.6.3 of this Standard?

Rotary Torque:Axial Force:		
Was the maximum operating torque or force required to adjust the device of the maximum allowed in ASME A112.18.1/CSA B125.1?	equal to or les O Yes	s than O No
Life Cycle Tests For operating controls: Prior to starting the test, the following conditions were established:		
psi (kPa) flowing as measured at the inlets°F (°C) measured at the outletGPM (kPa) flow rate		
Device's maximum outlet temperature adjusted to	°F (	°C)
Type of temperature and volume control:		
The temperature and volume control mechanism was cycled for at a rate of	cycles pe	cycles er min.
For internal elements: Prior to starting the test, the following conditions were established:		
psi (kPa) flowing as measured at the inletsoF (oC) measured at the outletGPM (L/m) flow rate		
Were the conditions in Table 1, Step 1 and Step 2 followed?	Oyes	О No
Each step was maintained for	seconds	
The internal elements were tested for	cycles	
Was the device then retested to Section 4.3, Working Pressure Test, follow Test?	ving the Life	Cycle O No
In Compliance?	Oyes	О No
Was the device then retested to Section 4.4, Maximum Torque or Force Ad	djustment Tes O Yes	ot? O No
In Compliance?	Oyes	O No
Was the device in complete compliance with Section 4.5?	Oyes	О No
Pressure and Temperature Variation Test Was the device installed in accordance with Figure 1 and the instructions of	of Section 4.6 O Yes	5.2? O No





For all types of devices:			
Inlet hot water supply pressure (G1)	psi	(	kPa
Inlet cold water supply pressure (G2)	psi	(	kPa
Inlet hot water supply temperature (T1)	°F	(	°C
Inlet cold water supply temperature (T2)	°F	(	°C
Temperature differential between T1 and T2	°F	(	°C
Were the inlet temperatures then maintained within $\pm2.0$ °F ( $\pm1.0$ °C	C)?	O Yes	O No
Outlet temperature at T3	°F	(	°C
Flow rate as measure at V3	$_{\rm BPM}$	(	L/min
Water was flowed through the device for			mir
Initial outlet set temperature	°F	(	°C
For Type P devices:			
Hot water supply pressure was decreased to	psi	(	kPa
Temperature changes at T3 were recorded for			sec
Largest temperature variation from the initial outlet set temperature	°F	(	°C
Hot water supply pressure was increased to	psi	(	kPa
Temperature changes at T3 were recorded for	poi	'	sec
Largest temperature variation from the initial outlet set temperature			
<u> </u>	°F	(	°C
Cold water supply pressure was decreased to	psi	(	kPa
Temperature changes at T3 were recorded for	poi	'	sec
Largest temperature variation from the initial outlet set temperature			
<u> </u>	°F	(	°C
Cold water supply pressure was increased to	psi	(	kPa
Temperature changes at T3 were recorded for	poi	'	sec
Largest temperature variation from the initial outlet set temperature			
	°F	(	°C
Was there any temperature variation exceeding $\pm 3.6$ °F ( $\pm 2.0$ °C) from temperature at the outlet temperature sensor T3?		initial ou O Yes	utlet set O No
For Type T devices:			
Hot water supply pressure was decreased to	nsi	(	kPa
Temperature changes at T3 were recorded for		`	sec
Largest temperature variation from the initial outlet set temperature			
	°F	(	°C
Hot water supply pressure was increased to	psi	(	kPa
Temperature changes at T3 were recorded for		`	sec
Largest temperature variation from the initial outlet set temperature			
	°F	(	°C
Cold water supply pressure was decreased to	psi	(	kPa
Temperature changes at T3 were recorded for		·	sec





	Largest temperature variation from the initial outlet set temperature	٥F	(	°C)
	Cold water supply pressure was increased to  Temperature changes at T3 were recorded for	psi	(	kPa) sec
	Largest temperature variation from the initial outlet set temperature	٥F	(	°C)
	Hot water supply temperature was increased to  Temperature changes at T3 were recorded for	٥F	(	°C) sec
	Largest temperature variation from the initial outlet set temperature	٥F	(	°C)
	During the first 5 seconds following a temperature change at sensor T3, we temperature spike greater than $+5.4$ °F ( $+3.0$ °C) for more than 1.5 sec $-9.0$ °F ( $-5.0$ °C) for more than 1.0 sec?	or g		ONO
	After the initial 5 seconds following a temperature change at sensor T3, we temperature spike greater than $\pm 3.6$ °F ( $\pm 2.0$ °C)?		there any O Yes	O No
	For Type T/P Devices: Test data for both Type P and Type T Devices must be submitted.			
	Was there an outlet temperature variation exceeding $\pm 3.6$ °F ( $\pm 2.0$ °C) set temperature at sensor T3?		the initial o	outlet O No
	Were all pressure changes specified in Section 4.6 accomplished in less th		I second? O Yes	ONO
	Was the device in complete compliance with the applicable criteria for type		device on t O Yes	test? O No
4.7	Water Supply Failure Test – All Types Was the device set up as shown in Figure 1 and in accordance with item (4.6.3?		o (f) of Sect	tion O No
	The cold water supply valve was closed within			sec
	Was the outlet temperature at T3 and the flow rate recorded for 5 seconds supply valve had been fully closed?		ter the cold O Yes	water O No
	The flow rate was reduced to Gl	PM	( within 5 s	_L/min) econds
	The hot water supply valve was closed within			sec
	Was the outlet temperature at T3 and the flow rate recorded for 5 seconds supply valve had been fully closed?		ter the hot o	water O No
	The flow rate was reduced to Gi	PM	( within 5 s	_L/min) seconds





	30% of the manufacturer's minimum rate flow is	GPM (	L/min)
	Did the device reduce the flow to 0.5 GPM (1.9 L/min) or 30% rated flow, whichever is less, within 5 seconds?	of the manufacturer O	$\sim$
	Upon cold water failure, did the device reduce the flow to 0.5 manufacturer's minimum rated flow, whichever is less, prior to	the water temperatu	re at T3
	exceeding 120.0 °F (48.9 °C)?	O Ye	s O No
4.8	Mechanical Temperature Limit Stop Test		
	Hot water inlet pressure	psi (	kPa)
	Cold water inlet pressure	psi (	kPa)
	Flow rate through the device	GPM (	 L/min)
	Hot water inlet temperature	°F (	°C)
	Cold water inlet temperature	°F (	°C)
	Limit stop was set to an outlet temperature of	°F (	°C)
	With the device set at the full hot position and flowing for 1 m		
	temperature at T3?	°F (	°C)
	A torque of	LBf●in (	N●M)
	was applied to the temperature control handle/valve stem for		sec
	While applying the torque for 1 minute, what was the outlet to	emperature at T3?	
		°F (	°C)
	Did the outlet temperature while applying the torque exceed the applying the torque by 3.6 °F (2.0 °C) or greater?	ne outlet temperature O Ye	$\sim$
	Were there any observable fractures in the limit stop?	O Yes	s O No
4.9	Outlet Temperature and Flow Capacity Test		
	Hot water inlet pressure	psi (	L/min)
	Cold water inlet pressure	psi (	L/min)
	During this test, were the inlet temperatures maintained withir	+20°F(+10°C)	without
	exceeding specified limits?	O Ye:	$\sim$
	Valve V3 was adjusted to deliver	GPM (	L/min)
	Cold inlet temperature was set to	°F (	°C)
	Hot inlet temperature was set to	°F (	°C)
	After setting the device to the full cold position, the device wa	as adjusted to an outle	rt
	temperature of	°F (	°C)
	After flerring for 1 minutes the cutlet temporature was	°F (	°C)
	After flowing for 1 minute, the outlet temperature was and the flow rate was	GPM (	C) L/m)
	and the now rate was	GFIVI (	L/IN)
	Cold inlet temperature was set to	°F (	°C)
	Hot inlet temperature was set to	°F (	°C)



4.10



temperature of °F		ет 	°C)
After flowing for 1 minute, the outlet temperature was and the flow rate was GPM	`		°C) L/m)
The temperature limit stop was set to °F	: (		°C)
When the device was set to the full hot position and water flowed for 1 minutemperature was °F		e outle	t °C)
Cold inlet temperature was set to Hot inlet temperature was set to  "For Part of the Cold in temperature was set to the C	: (		°C)
After setting the device to the full cold position, the device was adjusted to a temperature of °F		et	°C)
After flowing for 1 minute, the outlet temperature was and the flow rate was GPM	`		°C) _L/min)
The temperature limit stop was set to °F	: (		°C)
When the device was set to the full hot position and water was flowed for 1 temperature was		e, the	outlet °C)
Cold inlet temperature was set to Hot inlet temperature was set to A minimum out temperature was maintained at  OF  OF  OF  OF  OF  OF  OF  OF  OF  O	(		°C) °C) °C)
After flowing for 1 minute, the outlet temperature was and the flow rate was GPM	`		°C) L/m)
Did the device fail to flow a minimum of 2.25 GPM (8.5 L/min) or the manufarated flow?	acturer O Ye		imum O No
Was the device able to be adjusted to a minimum outlet water temperature of (37.8 °C)?	f 100. O Ye		ONo
Was the device able to limit the outlet temperature to a maximum of 120.0 of	°F (48. O Ye		, O No
Hydrostatic Pressure Test With outlets blocked and seating members fully opened, The device's body we pressurized topsi for	vas i (		kPa) min
Was there any leakage from the device?	O Ye	es	O No





#### SECTION V 5.0

### 

Did the packing or literature specify the device's minimum flow rate, determined at a flowing

pressure of 45.0 psi (310.3 kPa)?

LISTED LABORATORY:				
ADDRESS:				
	FAX:			
TEST ENGINEER(S):				
If applicable:				
OUTSOURCED LABORATORY:				
ADDRESS:				
PHONE:	FAX:			
TEST ENGINEER(S):				
Scope of outsourced testing:				
We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.				
Signature of the official of the listed laboratory:	Signature			
Title of the official:	Date:			