

Errata for 2015 Uniform Plumbing Code – 4th Printing

The following are changes that we found after the fourth printing of the 2015 Uniform Plumbing Code. These changes may apply to your code book. Thank you.

Appendix L

Section L 603.4.1(1) – Revise the temperature conversion in the second paragraph, from “less than 90°F (32°C) above ambient” to “less than 90°F (50°C) above ambient”.

L 603.4.1 Space Heating and Water Heating. The use of a gas-fired or oil-fired space-heating boiler system, otherwise in accordance with Section L 603.0, to provide the total space heating and water heating for a building is allowed where one of the following conditions is met:

- (1) The single space-heating boiler, or the component of a modular or multiple boiler system that is heating the service water, has a standby loss in Btu/h (kW) not exceeding $(13.3 \times pmd + 400)/n$, where (*pmd*) is the probable maximum demand in gallons per hour, determined in accordance with the procedures described in generally accepted engineering standards and handbooks, and (*n*) is the fraction of the year where the outdoor daily mean temperature exceeds 64.9°F (18.28°C).

The standby loss is to be determined for a test period of 24 hours duration while maintaining a boiler water temperature of not less than 90°F (50°C) above ambient, with an ambient temperature between 60°F (16°C) and 90°F (32°C). For a boiler with a modulating burner, this test shall be conducted at the lowest input.

(portions of the text not shown remain unchanged)

10/19/2020