

October 5, 2009

Steven J. Nastruz
Public Health, Seattle
And King County
19600 20th Ave NW
Shoreline, WA 98177

Re: Formal Interpretation letter ballot results FI003
Final Closing Date: September 30, 2009
2006/2009 Uniform Plumbing Code

Dear Mr. Nastruz:

I am transmitting to you herewith the following final ballot results.

The proposed Formal Interpretation asks the following question(s):

Question 1: In accordance with Section 413.1 are all public-use lavatories required to be limited to a maximum temperature of 120°?

Answer: Yes

Question 2. Does Section 413.1 only apply to fixtures designated as use for persons with disabilities?

Answer: No

The proposed Formal Interpretations were balloted through the Plumbing Technical Committee in accordance with Section 6 Formal Interpretations and achieved the necessary three-fourths majority agreement for both questions in accordance with Section 6-3.4.

Ph: 909.472.4100 • Fax: 909.472.4150 • www.iapmo.org

International Association of Plumbing and Mechanical Officials
5001 East Philadelphia Street • Ontario, California – USA 91761-2816



In accordance with Section 6-4.2 of the Regulations Governing Committee Projects, this formal interpretation shall apply to the 2006 and 2009 editions of the *Uniform Plumbing Code*. Please note that the effective date of the formal interpretation will be 20 days from the date of this letter, unless an appeal is filed with the IAPMO Standards Council in accordance with Section 1-6 of the Regulations Governing Committee Projects.

Sincerely,



Lynne Simnick
Director of Code Development

CC: Members of the Plumbing TC
IAPMO Standards Council
Gabriella Davis, Secretary, Standards Council
Matt Sigler, Staff Liaison

