



**Summary of Substantive Changes
between the 2008 and the 2014 editions of
ASTM F2623 “Polyethylene of Raised Temperature (PE-RT) SDR 9 Tubing”**

Presented to the IAPMO Standards Review Committee on March 9, 2015

General: The change to this standard will have an impact on currently listed products. The substantive change is:

- Added a new requirement to mark the tubing with the standards of applicable fitting systems with which this tubing is intended to be used (see Section 9.1.8).

Section 9, Marking: Added a new requirement to mark the tubing with the standards of applicable fitting systems with which this tubing is intended to be used as follows:

9.1 Marking on the tubing shall include the following, spaced at intervals of not more than 5 ft:

[9.1.8 Standard designation\(s\) of the fitting systems\(s\) for which the tubing is recommended for use by the tubing manufacturer.](#)