



**Summary of Substantive Changes
between the 2011 edition and Update No. 1 dated September 2015 of
CSA B64.0, “Definitions, general requirements and test methods for
vacuum breakers and backflow preventers”**

Presented to the IAPMO Standards Review Committee on November 9, 2015

General: General: The change to this standard may have an impact on currently listed products. The major change is:

- Included the requirement of NSF/ANSI 372 compliance for devices intended to carry water for human consumption (see Section 4.1.3)

Section 4.1 Materials: Included the requirement of NSF/ANSI 372 compliance for devices intended to carry water for human consumption as follows:

[4.1.3](#)

[Devices intended to convey or dispense water used for human consumption, through drinking or cooking, shall not contain a weighted average lead content in excess of 0.25% when evaluated in accordance with NSF/ANSI 372.](#)