



**Summary of Substantive Changes
between the 2010 edition including Update No. 1, dated March 2011
and the 2010 edition including Update No. 2, dated October 2015
of
CSA B356 “Water pressure reducing valves for
domestic water supply systems”**

Presented to the IAPMO Standards Review Committee on November 9, 2015

General: General: The change to this standard may have an impact on currently listed products. The major change is:

- Included the requirement of NSF/ANSI 372 compliance for devices intended to carry water for human consumption (see Section 4.1.1A)

Section 4.1 Materials: Included the requirement of NSF/ANSI 372 compliance for devices intended to carry water for human consumption as follows:

[4.1.1A Lead content](#)

[Valves intended to convey or dispense water used for human consumption, through drinking or cooking, shall not contain a weighted average lead content in excess of 0.25% when evaluated in accordance with NSF/ANSI 372.](#)