



**Summary of Substantive Changes  
between the 2007 edition including Update No. 1, dated June 2007  
and the 2007 edition including Update No. 3, dated June 2017  
of  
CSA B483.1 “Drinking water treatment systems”**

**Presented to the IAPMO Standards Review Committee on October 15, 2018**

**General: General:** The change to this standard may have an impact on currently listed products. The major change is:

- Included the requirement of NSF/ANSI 372 compliance for devices intended to carry water for human consumption (see Section 4.1.1A)

Section 2, Reference publications: Added a referenced publication as follows:

**NSF International/ANSI (American National Standards Institute)**

[372-2016 Drinking water system components – Lead content](#)

Section 4, Design Requirements: Included the requirement of NSF/ANSI 372 compliance for devices intended to carry water for human consumption as follows:

**4.1.1A Lead content**

[Drinking water treatment systems and components that are sold separately and intended to convey or dispense water used for human consumption, through drinking or cooking, shall not contain a weighted average lead content in excess of 0.25% when evaluated in accordance with NSF/ANSI 372.](#)