



**Summary of Substantive Changes  
between the 2016 edition and the  
2016 edition including Errata, dated July 2017  
of  
CSA B602 “Mechanical Couplings for Drain, Waste,  
and Vent Pipe and Sewer Pipe”**

**Presented to the IAPMO Standards Review Committee on November 13, 2017**

**General:** The editorial change to this standard should not have an impact on currently listed products. The editorial changes are:

- Removed the reference to elastomeric end caps from the cautionary notes (see Section 1.1)

Section 1, Scope: Removed the reference to elastomeric end caps from the cautionary notes as follows:

1.1

*This Standard covers mechanical couplings that are used to axially join pipes and fittings in non-pressure drain, waste, and vent (DWV) piping systems and sewer piping systems located inside or outside buildings and above ground or underground.*

*Notes:*

1) Caution should be exercised when installing mechanical couplings ~~and elastomeric end caps~~ at low temperatures. The coupling ~~or elastomeric end cap~~ manufacturer should be consulted.

2) Caution should also be exercised when installing mechanical couplings ~~and elastomeric end caps~~ at the base of stacks, at cleanouts, or at offsets in a piping system (see Annex A).